

APPENDIX - VIII PROFORMA REGARDING SAFE DRINKING WATER, HEALTH AND SANITARY CONDITION

CERTIFICATE. No.

Date: 16.05.2023

It is certified that an inspection team headed by Dr. Fikarat (Name & Designation) From (Department) inspected the N.S. ACADEMY (School Name) Located at PEPAL, BISAULI (BUDAUN) (School Address) and found that the N.S. ACADEMY (School Name) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 1 Year.

Signature with Seal:

Name

Designation:

चिकित्सा अधीक्षक

स्वा० केन्द्र सैदपुर

बदायूँ

Dr. F. H. Dany

M.S. e.H. Sait per

To

School Name N.S. ACADEMY

Address PEPAL, BISAULI (BUDAUN)

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. TC9964230000000300f

Dated: 30/12/2023

It is certified that an inspection team headed by ANAMIKA From UTTAR PRADESH JAL NIGAM (RURAL BAREILLY inspected the N.S. ACADEMY SCHOOL, PEPAL, BUDAUN, UTTAR PRADESH on 28/12/2023 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. TC9964230000000300F dated 29/12/2023 of UTTAR PRADESH JAL NIGAM (RURAL), BAREILLY (PHED Lab) certified that the N.S. ACADEMY SCHOOL, PEPAL, BUDAUN, UTTAR PRADESH has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till

from - 30/12/2023 to 29/12/2024

Signature with Seal:

Name :

Designation :



Name & Address of the Office / Department : Chemist




To

MANAGER
N.S. ACADEMY SCHOOL
PEPAL, BUDAUN,
UTTAR PRADESH

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

		<h3 style="text-align: center;">Analysis Report</h3>					
		District Level Water Analysis Laboratory U.P.Jal Nigam (RURAL)					
		Near M.B.Inter Collage, Gandhi Nagar, Bareilly (U.P.)					
URN No :- TC996423000000300F							
Customer Details							
Office Name and Address		N.S. Academy School Pepal Budaun					
Ref Letter No & Date		0,		DATE - 29.12.2023		Report No.- LAB/BLY/2023-24/300	
Basic details of sample							
District	Badaun	Tehseel	Bisauli		Analysis Start Date	29.12.2023	
Village	-	Block	Wazirganj				
Habitation	-	Location	Pepal		Analysis Completion Date	30.12.2023	
Water Source	Submersible	Sample Code	PS-300				
Quantity of Sample	1 ltr	Date of Sample Collection	29.12.2023		Report Issue Date	30.12.2023	
Receiving Date	29.12.2023	Sample Collector	VIPIN KUMAR			Sample Depositor	Shiv sankar mishra
Environmental Condition							
Temperature			23°C		Humidity		59%
Technical Data of Analysis							
S.No.	Analysis Parameter	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref.Method of Analysis	
				Acceptable Limit	Permissible Limit		
1	Colour	(Hazen)	1	5	15	IS 3025 (Part 4):2021	
2	Odour	-	Agreeable	Agreeable	Agreeable	IS:3025(Part-5):2022	
3	Taste	-	Agreeable	Agreeable	Agreeable	IS:3025(Part-5):2022	
4	Turbidity	(NTU)	0.94	1.00	5.00	IS 3025 (Part 10) : 2022	
5	TDS	(mg/L)	266	500	2000	IS 3025 (Part 16) : 2022	
6	PH	-	7.62	6.5-8.5	6.5-8.5	IS 3025 (Part 11) :2022	
7	Iron	(mg/L)	0.3	1.00	1.00	IS:3025(Part-53):2014	
8	Sulphate	(mg/L)	0.63	200	400	IS 3025 (Part 24) : 2022	
9	Alkalinity	(mg/L)	238	200	600	IS 3025 (Part 23) : 2019	
10	Hardness	(mg/L)	188	200	600	IS 3025 (Part 21) : 2019	
11	Chloride	(mg/L)	10	250	1000	IS 3025 (Part 32) : 2019	
12	Calcium	(mg/L)	100	75	200	IS:3025(Part-40):2019	
13	Magnesium	(mg/L)	21.3	30	100	APHA 24thEdition 3500Mg Method B	
14	Fluoride	(mg/L)	0.345	1	1.5	IS:3025 (Part-60):2023	
15	Nitrate	(mg/L)	0.95	45	No relaxation	APHA 24th Edition 4500 Method B	
Note							
1. This Certificate refers only to the particular sample(s) submitted for testing.							
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.							
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.							
4. Sample will be stored up to 07 days (In case of non perishable items only) from the date of issue of tests reports unless otherwise specified.							
• Not in NABL Scop							

Email: - a.ansika05ant@gmail.com
U.P.J.N.BAREILLY (RURAL) Cont.No:- 7318253235


Prepared By
अनिल कुमार
 गुणवत्ता प्रबन्धक
 जल विश्लेषण प्रयोगशाला
 जिला लेवेली (ग्रामीण)


Approved By

Technical Manager